
	<p>EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p>REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	--	-----------------	--

ANERT


Agency for Non-conventional Energy and Rural Technology

**EXPRESSION OF INTEREST (EOI)
for
MANUFACTURERS & DISTRIBUTORS OF
SOLAR MODULE, BATTERY & PCU
(2018-19)**

Agency for Non-conventional Energy and Rural Technology
Law College Road, Vikas Bhavan PO, Thiruvananthapuram-695033, Kerala
Phone:(91-471)2334122,2334124,2331803(office), 2329854 Fax:(91-471)2329853
Web:<http://www.anert.gov.in> email:director@anert.in

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p>ANERT- TECH/317/2018- PE1(RTS)</p>
---	---	--------------------------------	---

1. Notice.....	3
2. Abstract.....	4
3. Solar Power Development Programme in Kerala-Opportunities.....	5
3.1 Introduction.....	5
3.2 E Market place for Renewable Energy Systems – buymysun.com.....	6
3.3 Akshaya -urja Centres.....	7
4. General Conditions of Empanelment	7
5. Technical Specifications- requirements for product listing.....	8
6. Important Dates.....	14
Annexure 1.Format for Covering Letter.....	15
Annexure 2. Bid Submission form.....	16
Annexure 3. Service Centre Details.....	18
Annexure 4. Undertaking by the Agency.....	19
Annexure 5. Organizational Strength and Organizational Chart.....	20
Annexure 6. Product volume already distributed in Kerala in last 5years.....	21

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

1. Notice

Expression of Interest in accordance with the attached qualification criteria, technical specification and financial terms and conditions are invited from reputed & experienced manufactures/distributors for the empanelment as empanelled agencies for the implementation solar power plants in Kerala.'

The offers has to be filed based on the qualification criteria and as per the bid submission guidelines.

The listed (approved) components can be opted by any of the integrator empanelled by ANERT based on mutually agreed terms and conditions with the manufacturer / Distributor.

The guidelines and documents for Expression of Interest can be downloaded from the website (www.anert.gov.in) of ANERT.


The duly filled EoI (containing all Annexure documents) has to be submitted to Director ANERT, Vikas Bhavan (PO), Thiruvananthapuram, 695 033, along with application fee of Rs.25000/- as DD in favour of Director, ANERT.

Thiruvananthapuram

Sd/-

26.09.2018

Director

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

2. Abstract


Reference No.	<u>ANERT-TECH/317/2018-PE1(RTS)</u>
Superscription	Invitation of Expression of Interest for Empanelment of Manufacturers / Distributors of battery, PCU and Solar Module for Solar Rooftop Programme in Kerala under Distributed Power generation.
Date of release of Invitation	09.01.2019
Date of submission EOI by the agencies	Continuing
Place of opening Submission by Agencies	Office of the Director, ANERT, Vikas Bhavan. PO, Thiruvananthapuram – 695 033, Kerala
Application fee	Rs.25000/-
How to obtain the application form for submitting EoI	To be downloaded from the website of ANERT www.anert.gov.in/

Thiruvananthapuram

26.09.2018

Sd/-

Director

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--


3. Solar Power Development Programme in Kerala-Opportunities

3.1 Introduction

Agency for Non-conventional Energy and Rural Technology (ANERT) is an autonomous organization established in 1986 under the Societies Act by the Government of Kerala. The objective of the Agency is to gather and disseminate useful knowledge in various fields of Non-Conventional Energy, Energy conservation and Rural Technology. ANERT is the State Nodal Agency (SNA) for the Ministry of New and Renewable Energy (MNRE), Govt. of India, to carry out centrally assisted programmes on Renewable Energy in Kerala.

Renewable energy development has become ever more significant in the present day context, for its potential to decelerate the impact of climate change, to augment energy availability, to conserve conventional energy and control the individual energy expenses. Utilizing the freely available abundant renewable energy sources like the solar energy, bioenergy and so on is indispensable for Kerala, a State that has to import more than half of the total electricity demand. However, this requires coordinated efforts to ensure wider participation of people as well as planners and developers.

State had announced a target of 1000MW generation from solar by 2021. Out of this 500MW from Rooftop solar Power Plants. As nodal agency to promote renewable energy in the state of Kerala, it is the mandate of ANERT to create an ecosystem system for achieving the target. ANERT proposes to empanel Manufactures and integrators / Contractors for implementing projects in Kerala. Empanelment will be based on their Technical Criteria, Financial Criteria, Experience criteria and mechanism for service and maintenance.


	<p style="text-align: center;">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p style="text-align: center;">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	--	---	--

In this context ANERT is inviting Expression of Interest from Manufacturers of Solar Modules, PCU and Batteries for Empanelment in Solar Rooftop Programmes in the state of Kerala.

3.2 E Market place for Renewable Energy Systems – buymysun.com

We have already established an E- Market place (First ever in India by a State Nodal agency) for Renewable Energy.

- This e-Marketplace is an intermediate platform for empanelled vendors of ANERT to sell to customers in Kerala to buy renewable energy products. The vendor/Seller Portal and buyer/client portal will be managed in the E Market Place.
- To sell/buy a product the seller/ buyer first has to get empanelled with ANERT and then ANERT will allow them to register their details in the E- market place and get the credentials.
- Manufactures/ distributors can enlist their product in the marketplace, by submitting product details including images, test certificates, etc. meeting ANERT requirements.
- In the case of distributors, an authorisation letter from the manufacturer stating that they are the sole distributor need to be submitted.
- On listing of the product, integrator has only to select from the list for opting a product. Based on the status updating from the manufacturer the availability product can also be ensured before offering system to the customer.
- ANERT can invite rate contract for any of the product, if required for a particular scheme and this process will be limited to already empanelled manufactures / distributors only.

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

- In such cases payment shall be effected by ANERT or ANERT authorised persons through ‘www.buymysun.com’ portal and payment will be credited on line to the account.
- Features such as Online Product reviews and ratings, Offering online promotions and rewards, will also be made available in due course.
- The E-marketplace will also get integrated with the CRM/ service-support portal being developed by ANERT, which are linked to the Urja Mitra service centres.

3.3 Akshaya -urja Centres

ANERT had established 140 Akshaya Urja centres throughout Kerala. This is to provide proper service and maintenance to the customers as soon as possible. Manufactures/ Integrators can avail this service also.

- They can have a tie up with these centres to provide an initial complaint check up in case their service personnels are not immediately available.
- Master trainers from Manufactures/ Integrators may also be provided to train the technicians of Akshaya-urja for their respective components.

4. General Conditions of Empanelment


4.1 The agency should have positive net worth

4.2 The agency should have a valid GST registration.

4.3 The agency should have a service facility in Kerala to meet the time line for service.

4.4 Agency has to submit an undertaking regarding supply and service conditions with ANERT.

4.5 Registration certificate of the firm which is issued by registrar of companies or other competent authority under which firm is registered has to be submitted.

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

4.6 The Agency should submit the application fee of Rs.25,000/- (Rupees Twenty Five Thousand only) as DD in favour of Director ANERT payable at Thiruvananthapuram.

4.7 Agency has to submit the list probable list of products proposed to be listed in ANERT

4.8 On Empanelment agencies will be provided with user name and password so that they can add product details for listing in ANERT site.

4.9 Product submitted should comply all technical requirements by ANERT and required valid certifications has to be submitted online.

4.10 The quantity available may also to be updated so that Integrator can intend for that before accepting work order from the beneficiary.

4.11 3% spares has to be maintained at service facility in Kerala

4.12 All the warrantee conditions should be as per ANERT guidelines.

4.13 A copy of warrantee card has also be provided to end user


4.14 Any changes/ updates in MNRE guidelines will be binding on all the stakeholders.

4.15 Director, ANERT reserves the right to add, remove, and clarify any of the terms and Conditions contained herein.

4.16 Manufacturers should also provide an operational manual, Do's and Don'ts along with the video link for their corresponding products.

4.17 While a product is supplied, internal (factory) test certificate / conformity certificate should be provided


4.18 All the lists/ announcements including dates related to the empanelment process, will be published on ANERT's website (www.anert.gov.in) and ANERT will not be responsible for delays or non-receipt of individual communications in this regard, if any.

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

5. Technical Specifications- Requirements for product listing

5.1. SPV Modules

- (a) Only crystalline silicon cell PV modules of 200Wp or higher capacity should be submitted for empanelment
- (b) Shading correction/ bypass for optimizing array out to be incorporated in each solar module or panel level and shading optimization to be provided.
- (c) Each PV module used in any solar power project must use a RF identification tag (RFID), which must contain the following information. The RFID can be inside or outside the module laminate, but must be able to withstand harsh environmental conditions.
 - (a) Name of the manufacturer of PV Module
 - (b) Name of the manufacturer of Solar cells
 - (c) Month and year of the manufacture (separately for solar cells and module)
 - (d) Country of origin (separately for solar cell and module)
 - (e) I-V curve for the module
 - (f) Peak Wattage, I_m , V_m and FF for the module
 - (g) Unique Serial No. and Model No. of the module
 - (h) Date and year of obtaining IEC PV module qualification certificate
 - (i) Name of the test lab issuing IEC certificate
 - (j) Other relevant information on traceability of solar cells and module as per ISO 9000 series
- (d) The following details should be provided on the module
 - i. Name of the manufacturer
 - ii Month and year of manufacture
 - iii.Rated Power at STC
 - iv. V_{mp} , I_{mp} , V_{oc} , I_{sc}

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p>ANERT-TECH/317/2018-PE1(RTS)</p>
---	---	--------------------------------	---

- (e) The PV modules must qualify (enclose Test Reports/Certificates from IEC/NABL accredited laboratory) as per relevant IEC/BIS standard. The Performance of PV Modules at STC conditions must be tested and approved by one of the IEC/NABL Accredited Testing Laboratories.
- (f) PV modules used in solar power plants/ systems must be warranted for their output peak watt capacity, which should not be less than 90% at the end of 10 years and 80% at the end of 25 years.


S/N	System Component	Capacity/ rating	Minimum Technical Compliance
1.	Solar panel	As per the rating system selected	IEC 61215 / IS14286; IEC 61730 Part 1 & II; IEC61701 BIS Certificates With minimum efficiency of 16%

5.2. POWER CONDITIONING UNIT (PCU)- (Grid tied)


S/N	System Component	Minimum Technical Compliance
2.	Grid Tied Inverter	IEC 61683 / IS 61683 (Efficiency 95% and above) IEC 60068-2 (1, 2, 14, 30) /Equivalent BIS Std. IEC 62116 –for islanding prevention Compliance to CEA (Distributed generation) regulation, 2013, IEC 61727 for utility interface

Technical Specification:

Output voltage	<p>1 Phase, 230 V</p> <p>3 phase, 415 VAC</p> <p>Inverter/ PCU should be capable of synchronise with grid voltage between 110% and 80% of the rated output. Beyond this system</p>
----------------	--


	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p>ANERT-TECH/317/2018-PE1(RTS)</p>
---	---	--------------------------------	---

	has to stop generating.
Over Voltage / Under Voltage trip	When Voltages reaches above 110% or below 80% respectively, with clearing time up to two seconds for reconnection.
Frequency	50 Hz. Inverter/ PCU should be capable to synchronise with grid for a variation of frequency between 50.5 Hz and 47.5 Hz. Beyond this system has to stop generating.
Over and Under frequency Trip	High frequency at 50.5 Hz and low frequency at 47.5 Hz clearing time upto 0.2 seconds.
Continuous rating	Rated capacity of the configuration.
Nominal Power	Rated power should not be less than the rated capacity of the SPV array at STC.
Total Harmonic Distortion	Less than 5%
Operating temperature Range	-50 to 60°C
Housing cabinet	PCU to be housed in suitable switch cabinet, Within IP 21 (Indoor)/ IP 54 (Outdoor) or higher
PCU efficiency	95% and above at full load.
Power Control	MPPT
Harmonic Current Injections	Shall not exceed the limits specified in IEEE519
Direct Current Injection	Less than 0.5 % of the full rated output at the interconnection point.
Flicker	Should be within the limits specified in IEC 61000
Synchronisation	Automatic (Built into the inverter)
Hysteresis required for reenergizing	Sixty seconds at stabilized condition.
Power Factor	The PCU power factor at the point of distribution Licensee service connection shall be 0.95 lagging or leading when operating at

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

	above 25 percent of the rated output.
Maximum time for cease to Energise in the case of formation of an unintended Island	2 Seconds

- (a) The PCU shall not produce Electromagnetic interference (EMI) which may cause malfunctioning of electronic and electrical instruments including communication equipment, which are located within the facility in which the PCU is housed.
- (b) The PCU shall have an appropriate display on the front panel to display the instantaneous AC power output and the DC voltage, current and power input. Each of these measurement displays shall have an accuracy of 1 percent of full scale or better. The display shall be visible from outside the PCU enclosure. Operational status of the PCU, alarms, trouble indicators and AC and DC disconnect switch positions shall also be communicated by appropriate messages or indicator lights on the front of the PCU enclosure.
- (c) The PCU shall include an easily accessible emergency OFF button located at an appropriate position on the unit.
- (d) The PCU shall include ground lugs for equipment and PV array grounding.
- (e) All exposed surfaces of ferrous parts shall be thoroughly cleaned, primed, and painted or otherwise suitably protected to survive a nominal 30 years design life of the unit.
- (f) The PCU enclosure shall be weather proof and capable of surviving climatic changes and should keep the PCU intact under all conditions in the room where it will be housed. The inverter shall be located indoor and should be either wall/ pad mounted. Moisture condensation and entry of rodents and insects shall be prevented in the PCU enclosure.
- (g) Components and circuit boards mounted inside the enclosures shall be clearly identified with appropriate permanent designations, which shall also serve to identify the items on the supplied drawings.
- (h) Maximum Power Point Tracker (MPPT) - MPPT shall be integrated in the PCU to maximize the energy drawn from the array. The MPPT should be microprocessor based to minimize the power losses.

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p>ANERT-TECH/317/2018-PE1(RTS)</p>
---	---	--------------------------------	---

5.3 POWER CONDITIONING UNIT (PCU)- (Off Grid)


Minimum Technical requirements

S/N	System Component	Minimum Technical Compliance
1	Power conditioning Unit- Off Grid	IEC 61683 / IS 61683 IEC 60068-2 (1, 2, 14, 30) / Equivalent BIS Std
2	Power Factor	The PCU power factor at the point of distribution Licensee service connection shall be 0.95 lagging or leading when operating at above 25 percent of the rated output.
3	Continuous rating	Rated capacity of the configuration.
4	Nominal Power	Rated power should not be less than the rated capacity of the SPV array at STC.
5	Total Harmonic Distortion	Less than 5%
6	Operating temperature Range	-50 to 60°C
7	Housing cabinet	PCU to be housed in suitable switch cabinet, Within IP 21 (Indoor)/ IP 54 (Outdoor)
8	PCU efficiency	85% and above at full load.

5.4 Battery


Flooded type lead acid tubular battery/ VRLA/ Gel battery can be listed. Suitable ceramic vent plugs with float level indicators should be provided with the batteries

System Component	Minimum Technical Compliance
Battery	IS1651/IS13369 /IEC 61427/IS15549

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

6. Important Dates

Sl. No.	Information	Details
1	Last date and time for submission of proposal	Continuing
2	Place, Date and Time of opening of proposals	<p>Place: ANERT, Law College Road, VikasBhavan P. O. Thiruvananthapuram</p> <p>Date and Time: will be notified later</p>
3	Officer in-charge for correspondence and address for communication	<p>Ms. Devi Sivaraman</p> <p>Project Engineer</p> <p>Ph: 8113064928</p> <p>E-mail : empanel@anert.in</p>

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

Annexure 1.Format for Covering Letter

Sir,

I/We,....., hereby express my/our interest to be included as an Empanelled Manufacturers in Kerala under Solar Rooftop Power Plant Programme, as per the terms, conditions and the technical specifications, decided by Agency for Non-conventional Energy and Rural Technology (ANERT) and Ministry of New and Renewable Energy (MNRE).

I am/we are remitting herewith the required amount of Rs. 25,000/- as application fee as DD No. Dateddrawn on bank in favour of Director, ANERT payable at Thiruvananthapuram.

Yours faithfully

Place:

Signature


Date:

Name

Designation

(Office Seal)


(This letter to be submitted on the official letter head of the Agency, signed by the authorised signatory.)

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

Annexure 2. Bid Submission form

(to be submitted by all agencies)

1.	Name of the bidder as in registration certificate (Copy of registration certificate to be enclosed)			Flag-1
2.	Address in full			
3	GST No (Enclose a Copy of GST registration Certificate)			Flag-2
4.	Details of application fee Submitted Amount ,DD No, Bank and date Enclose DD of Rs.25000/- in favour of director , ANERT			Flag-3
	Positive net worth (Enclose Certificate from Registered Chartered accountant in this regard)		Yes/No	Flag-4
3.	Contact Details	Mobile		
		Land Phone		
		Fax No		
		Email		
4.	Bank account details of the Bidder	Account No		
		Name of account holder		

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

		Bank		
		Branch Name		
		Address of the bank		
		IFS code		
5.	Name of the authorised signatory (Power of attorney to be enclosed)			Flag-5
6.	Designation of the authorised signatory			
7	Service Centre in Kerala Please provide registration certificate. In case of 3 rd Party managed service centres, Submit copy of MoU/ agreement			Flag-6
8	In case of sole distributor, enclose authorisation letter from Manufacturer			Flag 7

The details furnished above are true and correct and complete to my knowledge and belief. All the details furnished are supported by documentary evidence.


Date

Signature of the authorised signatory

Name

Designation

(Office Seal)

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

Annexure 3. Service Centre Details

Sl. No.	District	Address of Service Centre	Own/ others	If other- mode of appointment	Contact person	Contact No./ Email ID	Copy of agreement/MOU Enclosed/Not enclosed

It is certified that the details furnished above are true and correct to my knowledge and belief.


Date

Signature of the authorised signatory

Name

Designation

(Office Seal)


	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

Annexure 4. Undertaking by the Agency

(In stamp paper worth Rs. 200/- (Rupees Two hundred only))

I (Name, Designation) authorised signatory of
.....
..... (Name and full address of the bidder) hereby undertake that

1. We are not blacklisted/ De-registered/ debarred by any Government department/ Public Sector Undertaking/ Private Sector/ or any other agency for which we have Executed/ Undertaken the works/ Services during the last 5 years.
2. We have service facility in Kerala to meet the time line for service. Attending a complaint in 48 hrs. and rectifying it in 7 days
3. We will submit products having necessary compliance and valid certifications only for approval
4. We will update on product availability in ANERT website .
5. 3% spares will be maintained at service facility in Kerala for immediate support for customers.
6. In the case systems products supplied under ANERT schemes, warrantee conditions specified by ANERT will be followed.
7. A copy of warrantee card has also be provided to end user and the warrantee will be honoured, directly to end user if it is in demand.
8. Director, ANERT reserves the right to add, remove, and clarify any of the terms and conditions contained herein.
9. We will provide an operational manual, Do's and Don'ts along with products.
10. Internal (factory) test certificate / conformity certificate will be provided with each product.

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

11. The certification of this product is from MNRE/ NABL/IEC/BIS approved labs.


Date

Signature of the authorised signatory

Name

Designation

(Office Seal)

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

Annexure 5. Organizational Strength and Organizational Chart

	Graduate	diploma	skilled	non-skilled
Engineering :				
Manufacturing				
Quality				
Commercial / Service after sales :				
Others :				
Total				


Date

Signature of the authorised signatory

Name

Designation

(Office Seal)

	<p align="center">EXPRESSION OF INTEREST (EOI) for MANUFACTURERS & DISTRIBUTORS OF SOLAR MODULE, BATTERY & PCU (2018-19)</p>	<p align="center">REF. NO.</p>	<p><u>ANERT- TECH/317/2018- PE1(RTS)</u></p>
---	---	--------------------------------	--

Annexure 6. Product volume already distributed in Kerala in last 5years

Sl. No.	Product Category Solar module/PCU/Battery	Total Production In kWp/kW/Whr	Distribution in Kerala In kWp/kW/Whr

Date

Signature of the authorised signatory

Name

Designation

(Office Seal)