

ANERT**Agency for Non-conventional Energy & Rural Technology****TENDER DOCUMENT**

Supply and Installation of 15 kWp SPV Off-grid power plant at ANERT HQ Smart Building, near PMG, Thiruvananthapuram, Kerala

Tender No. : 12/SPV/ANERT/2012**Last date for Tender Submission:
16.03.2013, 12:00 noon****ADDENDUM****Agency for Non-conventional Energy & Rural Technology**

TC No. 14/649, Thycaud PO, Thiruvananthapuram – 695 014, Kerala

Phone: (91-471) 2338077, 2334122, 2333124, 2331803 • Fax: (91-471)2329853

Web: <http://www.anert.gov.in> **email:** director@anert.in

Amendments to Tender No.: 12/SPV/ANERT/2012

The clauses mentioned below are modified as follows:

S/N	Page no.	Section	Clause no.	Clause revised to read as
1	22	20. SPV Modules	20.1	Only indigenously manufactured, mono crystalline silicon cell (5kW _p), poly crystalline silicon cell (5kW _p) & thin film (5kW _p) PV modules of 100W_p or higher capacity should be used in the power plant
2	24	21. Power Conditioning Unit	21.11	A minimum of 48 volt DC to 400 volt AC (3 phase) or 230 volt AC (single phase) inverter for 5kW _p system. Rated capacity of inverter should be 5kVA (3 nos. of 5kVA)
3	24	21. Power Conditioning Unit	21.12 (c)	Output voltage: 400 volt $\pm 2\%$ for 3 ϕ or 230 volt $\pm 2\%$ for 1ϕ
4	39.	Price Bid – Condition	1.	The rate quoted should be ALL INCLUSIVE including delivery of materials at the locations specified, and the cost of materials and labour for the civil works, erection and commissioning, warranties, taxes and duties. For Channel Partners of MNRE, subsidy available should be indicated separately as per Annexure III-A.

III-A – SUBSIDY INFORMATION

(To be filled in ONLY by bidders who are Channel Partners accredited by MNRE, Govt. of India for “Off-grid and Decentralised Solar applications under JNNSM – Solar photovoltaic”)

Sl. No.	Item	capacity	Basic Price (all inclusive except tax) (Rs.)	CST/ KVAT @ (Rs.)	All inclusive amount (Rs.)	Subsidy available under JNNSM (Rs.)	Net amount (Rs.)
[1]	[2]	[3]	[4]	[5]	[6] = [4]+[5]	[7]	[8] = [6][7]
1.	Power plant with mono crystalline PV module array and Battery (tubular flooded) bank	5 kW					
2	Power plant with poly crystalline PV module array and Battery (tubular flooded) bank	5 kW					
3	Power plant with thin film PV module array and Battery (tubular gel) bank	5 kW					
	GRAND TOTAL (*)						

Note: This data is only for information purpose, and would be considered only while effecting payment to the successful bidder after commissioning of the system. This data will not be considered for tender evaluation. MNRE Channel Partners not submitting this information are liable to be disqualified.

Date:

(seal)

Signature of the Bidder
(authorised signatory)

Name

Designation