

# TENDER DOCUMENT

## *Supply and Installation of 1400 nos. of Solar LED Street Lights*

**Tender No.: 4405/PUR/SLS/ANERT/2012**

**Last date for Tender Submission:  
05.11.2012, 12:00 noon**

## CORRIGENDUM

Dated 09<sup>th</sup> October 2012



**Agency for Non-conventional Energy & Rural Technology**

TC No. 14/649, Opp. Thycaud House, Thycaud. PO, Thiruvananthapuram – 695 014, Kerala

Phone: (91-471) 2334122, 2334124, 2331803 (office), 2329854 Fax: (91-471) 2329853

Web: <http://www.anert.gov.in> email: [director@anert.in](mailto:director@anert.in)

## **CORRIGENDUM TO TECHNICAL SPECIFICATIONS OF SOLAR LED STREET LIGHTING SYSTEM**

---

The clause "Light Output" under Broad Performance Specifications on page 23, is clarified as follows:

Light Output	White colour (colour temperature 5500°-6500°K) minimum 30 lux, when measured at the periphery of 4 meter diameter on a horizontal plane 4 metre below the luminaire. The illumination should be uniform without dark bands or abrupt variations, and soothing to the eye. Higher light output will be preferred.
--------------	--

These 2 pages (C-1 to C-2) of corrigendum shall be included in Envelope-B of the tender submission.